

ADDENDUM SIX to Bid #17-01

**Labor, Equipment and Materials to Install Sports Field Lighting Hillsborough
County Countywide Soccer Complex**

The following question was received, and answer follows:

In the written specification section 26 56 68, item 1.3 D

The first page of the photometric report for all luminaire types proposed showing horizontal and vertical axial candle power shall be provide to demonstrate the capability of achieving the specified performance. Reports shall be certified by a qualified independent testing laboratory with a minimum of five years experience or by a manufacturer's laboratory with a current accreditation under the National Voluntary Laboratory Accreditation Program for Energy Efficient Lighting Products. A summary of the horizontal and vertical aiming angles for each luminaire shall be included with the photometric report.

Is this to be submitted with the bid package on bid day for the County and TSA to evaluate?

ANSWER:

Yes, this information shall be submitted with the bid package.

END OF ADDENDUM