

ADDENDUM FOUR to Bid #17-01

**Labor, Equipment and Materials to Install Sports Field Lighting Hillsborough
County Countywide Soccer Complex**

The following question was received

Regarding

Sports Lighting
part 2 - Product

Section 2.1
C., System Description

#1 Galvanized steel poles and crossarm assemblies

In the past, because of the corrosive Florida soils, the County has allowed Galvanized steel poles as long as the steel is elevated a minimum of 2' above finished grade and the steel is not at ground level.

Is this the case here or will direct burial steel poles (in contact with the ground) be accepted?

Add the following to SPECIFICATION 26 51 00, PARAGRAPH 2.1, C., 1.:

“Steel poles shall be elevated a minimum of 2' above finished grade with a concrete base. Steel shall not be in direct contact with earth, and the steel shall not be at ground level.”

END OF ADDENDUM