

ADDENDUM THREE to Bid #17-01

**Labor, Equipment and Materials to Install Sports Field Lighting Hillsborough
County Countywide Soccer Complex**

The following question was received, answer follows question

1. Under section 26 56 68 - 1.2 a. Lighting Performance - It states the requirement for Light Loss Factor for HID be based on 0 .72 for maintained foot-candle design. Will any other design method be allowed? Or any other maintenance factor other than .72 be considered for this project?

No. No other light loss factor will be considered at this time.

END OF ADDENDUM