

ADDENDUM No. 1 – (July 25, 2016)

ADDENDUM TO: Golf Course Patios
BID NUMBER: 15-11
BID DUE DATE: Thursday, July 28, 2016 not later than 10:00am

TO BIDDER: This addendum is an integral part of the Bid file under consideration by you as a bidder in connection with the subject matter identified above. For the purpose of clarification the following additions, changes, modifications and replacements noted below have been made to the Bid and have been made to the Bid file which bears the above title.

Bids submitted shall conform to these additions and modifications noted herein and including all issued addendums.

CLARIFICATIONS TO QUESTIONS

1. Disposal of excess dirt and grass on site will only be allowed by Owner's permission and location to be coordinated with Golf Course Management.
2. Thicken edge of slab shall be accomplished by turning down at outside perimeter and creating a stem 12" deep by 8" wide with two continuous #4 steel dowels 3" from bottom of stem.
3. TSA shall provide water, contractor shall provide power.
4. No liquidated damages shall be assessed.
5. Both courses are located in City of Tampa. City of Tampa shall be the permitting agency.
6. No legal surveys or concrete testing will be required by TSA.
7. All landscaping to be retained shall be removed by Owner prior to commencement.
8. A 36" tall aluminum picket handrail shall be installed at the perimeter of the patio. Color and style to be approved by Owner and made a part of the permit drawings. An access opening 48" wide will be provided, location to be determined in field.
9. No retaining walls will be constructed. If required, an adjustment to the finish elevation of the patio and/or surrounding grade shall be made.

Note: To qualify your proposal, of which this addendum becomes a part, this form must be completed and returned to this office with the proposal.

Date: _____

Authorized Signature of Company Rep.

Printed Name of Company Rep.

Company: _____

Address: _____

Telephone: _____

Contact's Email: _____

END OF ADDENDUM #1 – BID #15-11