

ADDENDUM No. 1 – (March 31, 2017)

ADDENDUM TO: Service Level and Postage Stamp Concrete Flatwork Repair

BID NUMBER: 16-08

BID DUE DATE: Wednesday, April 5, 2017 not later than 10:00am

TO BIDDER: This addendum is an integral part of the Bid file under consideration by you as a Bidder in connection with the subject matter identified above. For the purpose of clarification the following additions, changes, modifications and replacements noted below have been made to the Bid and have been made to the Bid file which bears the above title.

Bids submitted shall conform to these additions and modifications noted herein and including all issued addendums.

ANSWERS TO QUESTIONS AT PRE BID MEETING

1. Notice to Proceed is anticipated by the end of April.
2. All patches shall be saw-cut if they occur on a control joint.
3. The materials used for the previous repair in 2015 were Sikadur 51 SL joint filler and Sikadur 21 Lo Mod LV epoxy mortar.
4. For repairs on exterior concrete walkways, neatly removed all damaged and spalled material completely prior to patching. If damage is extensive, it will be inspected in the field and determined whether it should be removed to the full depth of the slab.

Note: To qualify your proposal, of which this addendum becomes a part, this form must be completed and returned to this office with the proposal.

Date: _____

Authorized Signature of Company Rep.

Printed Name of Company Rep.

Company: _____

Address: _____

Telephone: _____

Contact's Email: _____