

ADDENDUM No. 1 – (August 27, 2018)

ADDENDUM TO: Parking Lot Resurfacing, RJS
BID NUMBER: 17-10
BID DUE DATE: Wednesday, August 29, 2018 not later than 10:00am

TO BIDDER: This addendum is an integral part of the Bid file under consideration by you as a bidder in connection with the subject matter identified above. For the purpose of clarification the following additions, changes, modifications and replacements noted below have been made to the Bid and have been made to the Bid file which bears the above title.

Bids submitted shall conform to these additions and modifications noted herein and including all issued addendums.

The following questions were received during and after the pre bid meeting. The answers provided shall become part of the scope of work and conditions of the bid.

1. ***Clarify the number of coats of product.*** Apply primer to entire parking area. Apply one (first) Ccoat of sealer to drive lanes only using a squeegee, then apply 2 more coats to entire parking lot using spray application. Recommended application rates are 0.12 to 0.15 gal/s.y. for first coat; 0.10 to 0.12 gal/s.y. for second coat; and 0.08 to 0.11 gal/s.y. for third coat.
2. ***Is power washing allowed for cleaning?*** Clean surface only by flushing.
3. ***What product was used when lot was restored in 2011?*** The product used was PMM (Polymer Modified Masterseal) by SealMaster.
4. ***Clarify the quantity of cracks requiring repair.*** It is the bidder's responsibility to determine the quantity of cracks requiring repair by visiting the site and examining the drawing notes and specifications.

Note: To qualify your proposal, of which this addendum becomes a part, this form must be completed and returned to this office with the proposal.

Date: _____

Authorized Signature of Company Rep.

Printed Name of Company Rep.

Company: _____

Address: _____

Telephone: _____

Contact's Email: _____

End of Addendum #1