

ADDENDUM No. 1 – (June 18, 2019)

ADDENDUM TO: Cart Barn Shoring, Rogers Park Golf Course

BID NUMBER: Bid #18-19

BID DUE DATE: Thursday, June 20, 2019 not later than 10:00am

TO BIDDER: This addendum is an integral part of the Bid file under consideration by you as a bidder in connection with the subject matter identified above. For the purpose of clarification, the following additions, changes, modifications and replacements noted below have been made to the Bid and have been made to the Bid file which bears the above title.

Bids submitted shall conform to these additions and modifications noted herein and including all issued addendums.

Questions and Responses

1. Since we are buying the shoring materials outright, who will be responsible for removing the shoring if/when the remodel happens?

Materials shall be considered part of the project. The removal will be in the remodel scope.

2. How should the wires be protected to prevent injury?

Fluorescent paint or wire markers.

3. Who will be obtain the permits and as-built drawings?

Contractor to obtain permits and a set of red lined markup drawings. These drawings submitted to TSA shall reflect as-built conditions.

4. With the current design, the straps at column A and F will restrict the opening of the garage doors. One of the contractors feels as though these two straps can be eliminated from the specs. Please clarify? Include the deduct as an alternate. 5. Does the 10 KIP shore include a 3:1 safety factor? Yes. 6. Is the temporary guy cable being used for lateral movement? The guy cable is designed to stabilize the structure from any movement. To qualify your proposal, of which this addendum becomes a part, this form must be completed *Note:* and returned to this office with the proposal. Date: _____ Authorized Signature of Company Rep. Printed Name of Company Rep. Company: Address: Telephone: Contact's Email: