

ADDENDUM No. 2 – (January 9, 2019)

ADDENDUM TO: Expansion Joint Repair, RJS
BID NUMBER: 18-06
BID DUE DATE: Thursday, January 10, 2019 not later than 10:00am

TO BIDDER: This addendum is an integral part of the Bid file under consideration by you as a bidder in connection with the subject matter identified above. For the purpose of clarification the following additions, changes, modifications and replacements noted below have been made to the Bid and have been made to the Bid file which bears the above title.

Bids submitted shall conform to these additions and modifications noted herein and including all issued addendums.

See attachment

Note: To qualify your proposal, of which this addendum becomes a part, this form must be completed and returned to this office with the proposal.

Date: _____

Authorized Signature of Company Rep.

Printed Name of Company Rep.

Company: _____

Address: _____

Telephone: _____

Contact's Email: _____

End of Addendum #2

ADDENDUM TWO to Bid #18-06

Expansion Joint Repair Raymond James Stadium

The following clarifications shall be incorporated into the Bid Documents:

1. Add Alternate#2 includes all work in both end zones.
2. Detail 8 and 9 are typical details and are described in the specifications. Section 07 95 00 part 2.3 lists expansion joint types EJ1, EJ2, and EJ4 are required to be fire rated. .
3. Voluntary Alternates for the fire rated systems will be considered.

END OF ADDENDUM TWO